



CSR, INC
 1131 BLUME RD, ROSENBERG, TEXAS 77471
 (281) 342-4492 (281) 342-9682



**PRE-INSPECTION OF ELECTRICAL CABLE
 BEFORE SERVICE**

Customer: _____ Location: _____
 Cable MFG: _____ Cable#: _____
 Cable Type: _____ Ambient Temp: _____
 Length: _____

MULTICONDUCTOR CABLE

RESISTANCE END TO END

Conductor 1: _____ Ohms.
 Conductor 2: _____ Ohms.
 Conductor 3: _____ Ohms.
 Conductor 4: _____ Ohms.
 Conductor 5: _____ Ohms.
 Conductor 6: _____ Ohms.
 Conductor 7: _____ Ohms.

Hipot 1,000 VDC – 5 Minutes Each Conductor: _____
 Meg 500 VDC – 1 Minute Each Conductor: _____

Comments: _____

Inspector: _____

Date of Inspection: _____

**POST-INSPECTION OF ELECTRICAL CABLE
 AFTER SERVICE**

Customer: _____ Location: _____
 Cable MFG: _____ Cable#: _____
 Cable Type: _____ Ambient Temp: _____
 Length: _____

MULTICONDUCTOR CABLE

RESISTANCE END TO END

Conductor 1: _____ Ohms.
 Conductor 2: _____ Ohms.
 Conductor 3: _____ Ohms.
 Conductor 4: _____ Ohms.
 Conductor 5: _____ Ohms.
 Conductor 6: _____ Ohms.
 Conductor 7: _____ Ohms.

Hipot 1,000 VDC – 5 Minutes Each Conductor: _____
 Meg 500 VDC – 1 Minute Each Conductor: _____

Comments: _____

Inspector: _____

Date of Inspection: _____